BUREAU OF FIRE PREVENTION FIRE DISTRICT #2 TOWNSHIP OF OLD BRIDGE 732-970-6542 PHONE 732-970-6545 FAX 8:00 – 4:00 OFFICE HOURS

IF MONITORED ALARM, SOMEONE MUST BE ON SITE WITH CODE TO PUT THE ALARM ON TEST. ALSO, A LEGAL ADULT MUST BE PRESENT DURING THE INSPECTION. THE INSPECTORS DO NOT GO INTO VACANT PREMISES.

YOUR APPOINTMENT HAS BEEN SCHEDULED FOR	AT
CERTIFICATE CAN BE PICKED UP THE FOLLOWING	DAY AFTER 12:00 PM.

MULTI-FAMILY SMOKE DETECTOR/CARBON MONOXIDE

- 1 SMOKE DETECTOR ON EACH LEVEL, INCLUDING BASEMENT
- 1 SMOKE DETECTOR WITHIN 10 FEET OF BEDROOMS. IF AT THE TIME OF HOME CONSTRUCTION SMOKE DETECTORS WERE HARD-WIRED AND/OR INTERCONNECTED, THEY MUST REMAIN THAT WAY (I.E. <u>DO NOT</u> REPLACE WITH BATTERY DETECTORS).
- 1 CARBON MONOXIDE DETECTOR WITHIN 10 FEET OF BEDROOMS
- THE FOLLOWING ITEMS WILL ALSO BE CHECKED:
 - 1. HOUSE IS PROPERLY NUMBER
 - 2. NO DOUBLE-KEY DEADBOLTS OR SLIDEBOLTS ALL EXTERIOR DOORS AS WELL AS OPERATION OF DOORS
 - 3. NO OPEN BREAKER SLOTS IN ELEC. BREAKER PANEL-BREAKER SWITCHES MUST NOT BE PAINTED & OPERATE PROPERLY
 - 4. OUTLET COVERS & SWITCHES NEED TO BE COVERED AND APPEAR TO BE IN PROPER WORKING ORDER
 - 5. NO PENETRATIONS WALLS, CLOSETS, CEILINGS, PIPE CHASES
 - 6. ALL INTERIOR ROOM DOORS SHOULD OPERATE PROPERLY
 - 7. FURNACE ROOM MUST BE COMPLETELY EMPTY-NO SHELVING, STORAGE, COMBUSTIBLE FLOOR COVERINGS (RUGS, CARPETING)
 - 8. IF INSTALLED, ALL GFI'S MUST BE IN PROPER WORKING ORDER
 - 9. DRYER PROPER VENTILATION. HOSE NEEDS TO BE METAL AND PROPERLY ATTACHED
 - 10. ATTICS NO STORAGE. ROOF FRAMING STRUCTURE MUST BE INTACT.
- FAILURE FOR ANY REASON WILL REQUIRE YOU TO MAKE AN ADDITIONAL APPOINTMENT FOR REINSPECTION BY CALLING THE OFFICE
- ALL REINSPECTIONS WILL REQUIRE AN ADDITIONAL FEE